



Notes:

** Tooled joint depth shall be a minimum of 20% of the total floor slab thickness.

LymTal International, Inc.

Scale:NTS

Drawn By: GAB

Date:10/4/04

Revised:

Sealant Detail Standard

"V" Joint Detail

Drawing Number: 1294-00